



# City of New London

Department of Finance-Purchasing Agent  
13 Masonic Street • New London, CT 06320 • Phone (860) 447-5215 • Fax (860) 447-5297

## Invitation for Bids

### ADDENDUM No. 3

**Bid No.:** 2015-09

**Addendum No.:** 3

**Date Issued:** October 21, 2014

**NLPD Exterior Concrete Staircase Removal and Replacement**

**Opening Date and Time:** Friday, October 24, 2014 at 2:00 P.M.

**Bidders Notes:** This addendum is issued to provide all bidders with notice of revisions/additions to the General Conditions and Specifications.

All other terms and conditions remain the same.

**This Addendum cover page must be signed and returned with your bid.**

\_\_\_\_\_  
Authorized Signature of Bidder

\_\_\_\_\_  
Company Name

### Return Bid To:

Alicia Smith, Purchasing Agent  
City of New London  
13 Masonic Street  
New London, CT 06320

**Bids cannot be accepted after the Bid Opening Date and Time indicated above.**



# City of New London

Department of Finance-Purchasing Agent

13 Masonic Street • New London, CT 06320 • Phone (860) 447-5215 • Fax (860) 447-5297

## Revisions/Additions to General Conditions and Specifications

- 1) Revised Section 5.4      The City of New London requests that a bid alternate be submitted by the Contractor to provide and install, prior to concrete curing, non-slip safety stair nosing. ***The alternate non-slip nosing will start 6” from each side of the brick walls and have an 18” gap at the center, centered on the railing. With each sept being 11’ in width, each step would have two (2) 4’-3” treads. Since the staircase has a total number of twenty (20) treads, total length of nosing shall be approximately 170 lf.*** Please see Detail 5 for further specifications.
  
- 2) Revised Section 5.2      SCOPE OF WORK      The proper demolition and removal of the existing concrete staircase known as the East Staircase of the New London Police Department Headquarters building. Upon completion of the initial demolition phase, the proposed reconstruction of the reinforced concrete staircase shall match the existing condition and dimension as best as practicable. The Contractor shall provide design and construction services, all necessary labor and materials, attention to finish detail and adherence to the specifications and noted herein. ***After the issuance of any contract award, should the City order any heating or tenting, or any other work not specified in the IFB or Addendums, a change order would be required.***