



City Of New London

Department of Finance-Purchasing Agent
13 Masonic Street • New London, CT 06320 • Phone (860) 447-5215 • Fax (860) 447-5297

Request for Proposals

ADDENDUM 1

Proposal No.: 2021-13

Addendum No.: 1

Date Issued: June 22, 2021

Repairs and Improvements at the Marina Parking Lot

Opening Date and Time: July 1, 2021 at 2:00PM

Bidders Notes: This addendum is issued to provide all potential bidders with answers to questions submitted.

All other terms and conditions remain the same.

This Addendum cover page must be signed and returned with your bid.

Authorized Signature of Bidder

Company Name

Return Bid To:

Joshua Montague, Accounting Purchasing Agent
City of New London
13 Masonic Street
New London, CT 06320

Bids cannot be accepted after the Bid Opening Date and Time indicated above

2021-13 Repairs and Improvements at the Marina Parking Lot

ADDENDUM 1

RE: 2021-13
FROM: Joshua Montague, Accounting Purchasing Agent
TO: Prospective bidders

This Addendum shall be part of the Contract Documents and modifies the original bidding documents. This Addendum is to be acknowledged by the bidders on the Bid Form. Failure to do so may subject the bidder to disqualification.

Changes to prior Addenda:

- No prior Addenda have been issued

Q&A:
Q1: On the 1 1/2" PE waterline there are no specifications on the type of PE pipe to the yard hydrants.
A1: Any type of PE is allowed as long as it meets building code for potable water systems. Type K copper is also allowed.

Q2: On the subject of the flared ends the smallest made is 12". Any suggestions?
A2: ADS makes a metal culvert end for 8" pipe. We also have seen PE flared ends for 8" but I'm not sure who the manufacturer is.....the metal end would be acceptable if the PE piece is not available.

<https://www.adspipe.com/water-management-solutions/specialty-fittings/metal-end-sections>

Q3: Is a job site trailer going to be required on this project?
A3: This is up to the contractor and City to decide. I don't think it's warranted for this simple parking lot repaving project.

General Items:

- Mandatory pre-bid meeting sign in sheet attached.

